

Vaslui, str. Donici nr. 23, cod postal 730150, Tel.: 0235/311153, Fax: 0235/322857

Nr. ord. reg. com. J37/692/2007, Cod Unic de Inregistrare nr.: 22586122

COD IBAN: RO81 RNCB 0259 0935 2480 0001, BCR Vaslui

Nr. 1357 din 25.03.2016

Catre:

S.C. AQUAVAS S.A. VASLUI
REGISTRATURA FAX
INTRARE NR. 433
IESIRE
Ziua 25 luna 03 anul 2016

BULETIN ANALIZA
CALITATE APA POTABILA

Nr. crt.	Indicatorul	U.M	Legea458: 2002, repu- blic. in 2011 CMA	Intrare statie				Iesire Statie
				Solesti	Bariad	Puscasi	Amestec	
1.	pH	Unitati de pH	$\geq 6,5 \leq 9,5$	8,38				8,11
2.	Conductivitate	$\mu S/cm^3$ la 20°C	< 2500	1012				1023
3.	Turbiditate	U.N.T.	≤ 5	14,44				0,75
4.	Oxidabilitate	mg. O ₂ / dm ³	≤ 5	4,60				3,12
5.	Aluminiu	$\mu g / dm^3$	200	8,2				183,1
6.	Amoniu - NH ₄	mg / dm ³	0,50	0,065				0,015
7.	Nitriti - NO ₂	mg / dm ³	0,50	0,012				sld
8.	Nitrati - NO ₃	mg / dm ³	50	0,39				0,47
9.	Cloruri	mg / dm ³	250	41,22				48,17
10.	Calciu	mg / dm ³		55,47				55,47
11.	Duritate totala	grade germane	>5	23,29				23,29
12.	Nr. total de colonii la 37° C	U.F.C. / cm ³	NOMA	-				-
13.	Streptococi fecali / 100ml	nr. / 100 cm ³	0	-				-
14.	Coliformi totali	nr. / 100 cm ³	0	-				-
15.	Nr. total de colonii la 22° C	U.F.C. / cm ³	NOMA	-				-

Sef laborator:
ing. Ciocan Georgiana

