

**DIRECTIA DE SANATATE PUBLICA JUDETEANA VASLUI**  
**LABORATOR DE DIAGNOSTIC SI INVESTIGARE IN SANATATE PUBLICA**  
**LABORATOR DE CHIMIE SANITARA - TOXICOLOGIE**  
 str. M- sal C-tin Prezan nr. 20  
 tel. 0235/362194- 362195  
 fax 0335 402282

acreditat pentru  
 ÎNCERCARE



SR EN ISO/CEI 17025:2005  
 CERTIFICAT DE ACREDITARE  
 LI 1022

**RAPORT DE INCERCARI FIZICO- CHIMICE NR. 44 VS- 14/ 08.07.2014**

**PROBE DE APA POTABILA RECOLTATE DE LA S.C. AQUAVAS S.A. VASLUI - SUCURSALA VASLUI cf. tabel:**

Data/ ora intrarii probelor in laborator: 07.07.2014 ora 11<sup>00</sup>

TRIMISE DE : AQUAVAS SUCURSALA VASLUI la data de : 07.07.2014

Data / ora recoltarii: 07.07.2014, orele 10<sup>15-45</sup>

PARAMETRUL ANALIZAT	Metoda de lucru	Amoniu mg NH <sub>4</sub> <sup>+</sup> /l	Nitriti mg NO <sub>2</sub> <sup>-</sup> /l	Nitrati mg NO <sub>3</sub> <sup>-</sup> /l	Oxidabi- litate <sup>Δ</sup> mg oxigen/l	Cloruri mgCl/l	pH unitati de pH	Turbiditate <sup>Δ</sup> UNT	Conduc- tivitate μS/cm (20 °C)	Aluminiu μgAl <sup>3+</sup> /l	Clor rez. liber <sup>Δ</sup> mgCl <sub>2</sub> /l	Culoare, gust, miros <sup>Δ</sup>
		Valoare admisa cf. Legii 458-2002 cu modificarile si completarile ulterioare	Max. 0.1* Max. 0.5**	Max. 50	Max. 5.0	Max. 250	6.5-9.5	≤ 5	Max. 2500	Max. 200	Max. 0.5** Min. 0.1**	Acceptabile consumatorului, fara modificari anormale
LOCUL RECOLTARII/ COD DE IDENTIFICARE PROBA												
Iesire rezervor/ 1379		0.031	-	1.30	-	-	-	-	-	185	0.46	-
Retea DISPECERAT AQUAVAS Vaslui/ 1380		sld (LOD=0.006 mg NH <sub>4</sub> <sup>+</sup> /l)	sld (LOD=0.004 mg NO <sub>2</sub> <sup>-</sup> /l)	1.28	4.22	-	7.726	1.65	791	180	0.28	-
Retea Piata Vidin/ 1381		-	-	-	-	-	-	-	-	-	0.30	-

**Precizari:**

- rezultatele determinarilor se refera la probele aduse spre analiza;
- analizele marcate cu " Δ " NU sunt acreditate RENAR
- sld=sub limita de detectie ( LOD)
- \* la iesirea din statie
- \*\* in retea de distributie

2 ex.

intocmit,  
 coordonator laborator  
 ing. Maria Manolachi



aprobat,  
 medic sef de departament S.S.P,  
 dr. Luminita Costache

Se interzice reproducerea partiala a raportului de incercari fizico- chimice fara acordul scris al laboratorului.

**DIRECTIA DE SANATATE PUBLICA JUDETEANA VASLUI  
LABORATOR DE DIAGNOSTIC SI INVESTIGARE IN SANATATE PUBLICA  
LABORATOR DE CHIMIE SANITARA - TOXICOLOGIE**

str. M- sal C-tin Prezan nr. 20  
tel. 0235/362194- 362195  
fax 0335 402282

acreditat pentru  
INCERCARE



SR EN ISO/CEI 17025:2005  
CERTIFICAT DE ACREDITARE  
LI 1022

**RAPORT DE INCERCARI FIZICO- CHIMICE NR. 47 VS- 14/ 22.07.2014**

**PROBE DE APA POTABILA RECOLTATE DE LA S.C. AQUAVAS S.A. VASLUI - SUCURSALA VASLUI cf. tabel:**  
Data/ ora intrarii probelor in laborator: 21.07.2014 ora 09<sup>00</sup>

**TRIMISE DE : AQUAVAS SUCURSALA VASLUI la data de : 21.07.2014**

Data / ora recoltarii: 21.07.2014, orele 08<sup>15-45</sup>

PARAMETRUL ANALIZAT	Metoda de lucru	Amoniu mg NH <sub>4</sub> <sup>+</sup> /l	Nitriti mg NO <sub>2</sub> <sup>-</sup> /l	Nitrati mg NO <sub>3</sub> <sup>-</sup> /l	Oxidabilitate <sup>Δ</sup> mg oxigen/l	Cloruri mgCl <sup>-</sup> /l	pH unitati de pH	Turbiditate <sup>Δ</sup> UNT	Conductivitate μS/cm ( 20 °C)	Aluminiu μgAP <sup>+</sup> /l	Clor rez. liber <sup>Δ</sup> mgCl <sub>2</sub> /l	Culoare, gust, miros <sup>Δ</sup>
		Valoare admisa cf. Legii 458-2002 cu modificarile si completarile ulterioare										
LOCUL RECOLTARII/ COD DE IDENTIFICARE PROBA		SR ISO 7150-1:2001	SR EN 26777 ISO 6777:2002// SR ISO 6777/A99:2002// SR EN 26777/C91: 2006	SR ISO 7890-3:2000	SR EN ISO 8467:2001	SR ISO 9297:2001	SR ISO 10523:2012	SR EN ISO 7027:2001	SR EN 27888:97	SR ISO 10566:2001	STAS 6364- 78	-
		Max. 0.50	Max. 0.1* Max. 0.5**	Max. 50	Max. 5.0	Max. 250	6.5-9.5	≤ 5	Max. 2500	Max. 200	Max. 0.5** Min. 0.1**	Acceptabile consumatorului, fara modificari anormale
Iesire rezervor/ 1451		0.011	sld	0.91	3.59	40.18	7.562	1.42	853	155	0.50	da
Retea DISPECERAT AQUAVAS Vaslui/ 1452		0.009	sld (LOD=0.004 mg NO <sub>2</sub> <sup>-</sup> /l)	0.86	3.64	-	7.705	1.53	797	165	0.36	s/c
Retea Piata Vidin/ 1453		-	-	-	-	-	-	-	-	-	0.37	-

**Precizari:**

- rezultatele determinarilor se refera la probele aduse spre analiza;
- analizele marcate cu " Δ " NU sunt acreditate RENAR
- sld=sub limita de detectie ( LOD)
- \* la iesirea din statie
- \*\* in retea de distributie

2 ex.

intocmit,  
coordonator laborator,  
ing. Maria Manolachi

aprobata  
medic sef departament S.S.P.  
dr. Luminita Costache

