

	AQUAVAS S.A. VASLUI SUCURSALA VASLUI Str. Alceu Ciobanu, nr. 23, Vaslui, Cod postal 730150, Romania NR. Inregistrare la Reg. Com. 357/082/2007 CUI: RO-17046823 CUI: 2500122 Cont. RO59 14003 0750 0264 5277 0015 deschis la BCR Vaslui	TUV	TUV	TUV
		CERT ISO 9001	PROFI ISO 14001	CERT ISO 14001

1. M2. TEST. Nr. 1117 din 11.11.2017
 14.2017

S.C. AQUAVAS S.A. VASLUI
 REGISTRATURA FAX
 INTRARE NR. 1019
 Zila 01 luna 11 anul 2017

BULETIN ANALIZA
CALITATE APA POTABILA

si

Luna OCTOMBRIE 2017

Nr crt.	Indicatorul	U.M.	Legen 458/2002	Intrare statie				Iosire Statie
				Solesti	Barad	Puscasi	Amestec	
1.	pH	Unitati de pH	> 6,5-9,5	8,11	8,30		8,14	7,37
2.	Conductivitate	μ S/cm	< 2500	726,45	1123,8		866	788,52
3.	Turbiditate	U.N.T	\leq 5	65,18	14,76		50,37	2,28
4.	Oxidabilitate	mg. O ₂ / dm ³	\leq 5	10,94	6,74		9,24	5,32
5.	Aluminiu	μ g / dm ³	200					95,67
6.	Amoniu - NH ₄ ⁺	mg / dm ³	0,50	0,057				sid
7.	Nitriti - NO ₂	mg / dm ³	0,50	0,025				0,008
8.	Nitrati - NO ₃	mg / dm ³	50					
9.	Cloruri	mg / dm ³	250	32,02	44,24		35,82	53,16
10.	Calciu	mg / dm ³	-	54,00				54,00
11.	Duritate totala	grade germane	\leq 5	17,62	26,36		20,58	18,08
12.	Nr. total de colonii la 36 ^o C	U.F.C / 1cm ³	NOMA	>300	>300		>300	0
13.	Enterococi fecali	nr. / 100 cm ³	0	22	37		21	0
14.	Bacterii coliforme	nr. / 100 cm ³	0	36000	7500		27000	0
15.	Clostridium perfringens	nr. / 100 cm ³	0	6	20		13	0
16.	Nr. total de colonii la 22 ^o C	U.F.C / 1cm ³	NOMA	>300	>300		>300	0

Sof laborator,
 ing. Musat Oana