

CS

	AQUAVAS S.A. VASLUI SUCURSALA VASLUI	TUV	PROFI	TUV
	Str. Alacu Donci, nr. 23, Vaslui, Cod postal 730150, Romania NR. Inregistrare la Reg. Com: J37/692/2007, CUI: RO 17961023, CUI: 2538122 Cont: RO59 RNCB 0250 0284 5277 0019, deschis la BCR Vaslui	ISO 9001	ISO 14001	ISO 14001

Nr. 592 din 27.01.2018*592/2018*

SC AQUAVAS SA VASLUI	
INTRARE NR:	<u>988</u>
DATA	<u>29</u>
LUNA	<u>01</u>
ANUL	<u>2018</u>

BULETIN ANALIZA
CALITATE APA POTABILA

Luna IANUARIE 2018

Nr. crt.	Indicatorul	U.M.	Legea 458/2002	Intrare statie				Iesire Statie
				Soesti	Barlad	Puscasi	Amestec	
1.	pH	Unitati de pH	> 6,5 < 9,5	8,16				7,58
2.	Conductivitate	$\mu S/cm^1$	< 2500	791,93				812,39
3.	Turbiditate	U.N.T.	≤ 5	24,92				0,92
4.	Oxidabilitate	mg. O ₂ / dm ³	≤ 5	7,21				4,32
5.	Aluminiu	$\mu g / dm^3$	200	8,45				38,84
6.	Amoniu - NH ₄ ⁺	mg / dm ³	0,50	0,126				0,020
7.	Nitriti - NO ₂ ⁻	mg / dm ³	0,50	0,014				sld(<0,003)
8.	Nitrati - NO ₃ ⁻	mg / dm ³	50	1,14				1,30
9.	Cloruri	mg / dm ³	250	30,99				44,02
10.	Duritate totala	grade germane	>5	19,33				19,49
11.	Nr. total de colonii la 36° C	U.F.C. / 1cm ³	NOMA	280				0
12.	Enterococi fecali	nr. / 100 cm ³	0	4				0
13.	Bacterii coliforme	nr. / 100 cm ³	0	22354				0
14.	Clostridium perfringens	nr. / 100 cm ³	0	0				0
15.	Nr. total de colonii la 22° C	U.F.C. / 1cm ³	NOMA	>300				0

Sef laborator,
ing. Musat Oana

Oana Musat