


	AQUAVAS S.A. VASLUI SUCURSALA HUȘI RO-17986823 Str. Ștefan cel Mare, nr. 18 ROMANIA C.U.I. 27913802, Nr.inregistrare la R.C.: J37/13/2011 Cont: RO10 BRDE 380SV30767583800 deschis la B.R.D. Huși				
	Tel.: 0235 481560; 0235 481288	Fax. 0235 471268	E-mail: aquavas.husi@gmail.com		

Nr.19/02.04.2021

Locul prelevării - Zona Cina
 Data /ora prelevării - 02.04.2021/h -9 :30
 Tipul probei - Apa tratata
 Proba a fost prelevata de - laborant Alecsa Steliana
 Punctul de prelevare - Rezervor consumator

DIRECTOR :
 ing. Zelincu V.



REZULTATELE ANALIZELOR FIZICO-CHIMICE

Nr. crt	Parametrul analizat	U.M	Valori obtinute	C.M.A Lg.458/2002(2011)	Metoda de analiza
1	Aluminiu	μg/l	70	200	SR ISO 10566/2001
2	Amoniu	mg/l	0.053	0,5	SR ISO7150-1/2001
3	Cloruri	mg/l	42.60	250	SR EN ISO9297 :2001
4	Clor rezidual liber	mg/l	0,23	>0,1<0,5	STAS 6364/78
5	Culoare	grad de culoare	Acce.	acceptabila consumstorilor	SR EN ISO 7887/2002
6	Gust	-	Acce.	Acceptabila consumatorilor	SR EN 1622/2007
7	Miros	-	-		SR EN 16622/2007
8	Oxidabilitate	mgO2/l	1.81	5	SR EN ISO 8467/2001
9	pH	Unitati pH	8.11	>6,5 :<9,5	SR ISO10523/2009
10	Turbiditate	UTF	0.72	<5	SR EN ISO7027/2001
11	Nitriti	mg/l	0.046	0,5	SR EN 26777/c 91/2006
12	Nitrati	mg/l	5.11	50	Sr iso 7890-3/2000
13	Conductivitate(20°C)	μs/cm	653	2500	SR EN27888/1997
14	Duritate totala	grad german	13.88	min.5	SR ISO6059/2008

Concluziile analizei :proba de apa analizata corespunde/ nu corespunde conf.

Legii458/2002privind calitatea apei potabile si lg. Modificata 311/2004

INLOC.SEF LABORATOR,
 Ing.Ciobanu Mihaiela



LABORANT,
 Alecsa Steliana

