


	AQUAVAS S.A. VASLUI SUCURSALA VASLUI Str. Alecu Donici, nr. 23, Vaslui, Cod postal 730150, Romania NR. înregistrare la Reg. Com.: J37/692/2007, CIF: RO-17868823, CUI: 2686122 Cont: RO69 RNCB 0259 0284 5277 0019, deschis la BCR Vaslui			
		73 100 3760	70 104 3760	73 116 3760

Nr. 2479 din 01.07.2019.



BULETIN ANALIZA
CALITATE APA POTABILA

Luna JUNIE 2019

Nr. crt.	Indicatorul	U.M.	Legea 458/2002	Intrare statie				Iesire Statie
				Solesti	Barlad	Puscasi	Amestec	
1.	pH	Unitati de pH	$\geq 6,5 \leq 9,5$	7,96		7,71	7,97	7,42
2.	Conductivitate	$\mu S/cm^1$	< 2500	830,30		681	804	850,50
3.	Turbiditate	U.N.T.	≤ 5	32,96		83,8	32,79	1,14
4.	Oxidabilitate	mg. O ₂ / dm ³	≤ 5	5,90		8,25	5,90	3,30
5.	Aluminiu	$\mu g / dm^3$	200	23,27		7,65	22,77	74,30
6.	Amoniu - NH ₄ ⁺	mg / dm ³	0,50	0,119		0,067	0,170	0,008
7.	Nitriti - NO ₂ ⁻	mg / dm ³	0,50	0,035		0,028	0,030	0,002
8.	Nitrati - NO ₃ ⁻	mg / dm ³	50	0,83		0,95	0,76	0,65
9.	Cloruri	mg / dm ³	250	33,71		36,36	41,46	47,47
10.	Duritate totala	grade germane	>5	20,23		23,82	20,23	20,13
11.	Nr. total de colonii la 36° C	U.F.C. / 1cm ³	NOMA	1450		2830		0
12.	Enterococi fecali	nr. / 100 cm ³	0	170		63		0
13.	Bacterii coliforme	nr. / 100 cm ³	0	37100		37350		0
14.	Clostridium perfringens	nr. / 100 cm ³	0	225		34		0
15.	Nr. total de colonii la 22° C	U.F.C. / 1cm ³	NOMA	1745		2800		0

Sef laborator,
Ing. Musat Oana

Musat