

	AQUAVAS S.A. VASLUI SUCURSALA VASLUI Str. Alecu Donici, nr. 23, Vaslui, Cod postal 730150, Romania NR. Inregistrare la Reg. Com.: J37/882/2007. CIF: RO-17986823, CUI: 2586122 Cont: RO50 RNCB 0250 0204 9277 0010, deschis la BCR Vaslui			
		Nr. <u>3046</u> din <u>31.07.2018</u>		

Nr. 3046 din 31.07.2018

112.707.
01.08.2018

SC AQUAVAS SA VASLUI	
INTRARE	NR.: <u>4134</u>
IESIRE	
Ziua <u>07</u>	Luna <u>08</u> Anul <u>2018</u>

Catre:

Sistemul de Gospodarie a Apelor Vaslui

Va transmitem valorile medii lunare ale principalilor parametri fizico-chimici si bacteriologici ai apei, monitorizati de Laboratorul Statiei de Tratare a Apei.

CSC

Luna IULIE 2018

Nr. crt.	Indicatorul	U.M.	Legea 458/2002	Intrare statie				Iesire Statie
				Solesti	Bartad	Puscasi	Amestec	
1.	pH	Unitati de pH	$\geq 6,5 \leq 9,5$	7,93		7,76	7,91	7,50
2.	Conductivitate	$\mu S/cm^3$	< 2500	787,52		831	803	802,83
3.	Turbiditate	U.N.T.	≤ 5	33,82		18,30	29,45	0,97
4.	Oxidabilitate	mg. O ₂ / dm ³	≤ 5	6,38		8,14	6,59	3,72
5.	Aluminiu	$\mu g / dm^3$	200	11,86				98,82
6.	Amoniu - NH ₄ ⁺	mg / dm ³	0,50	0,132				0,020
7.	Nitriti - NO ₂ ⁻	mg / dm ³	0,50	0,059				<0,003
8.	Nitrati - NO ₃ ⁻	mg / dm ³	50	1,16				1,36
9.	Cloruri	mg / dm ³	250	34,91		38,59	36,36	46,77
10.	Duritate totala	grade germane	>5	18,90		21,53	20,03	18,90
11.	Nr. total de colonii la 36 ^o C	U.F.C. / 1cm ³	NOMA	>300				0
12.	Enterococi fecali	nr. / 100 cm ³	0	29				0
13.	Bacterii coliforme	nr. / 100 cm ³	0	38157				0
14.	Clostridium perfringens	nr. / 100 cm ³	0	8				0
15.	Nr. total de colonii la 22 ^o C	U.F.C. / 1cm ³	NOMA	>300				0

Sef laborator,
ing. Musat Oana

Musat Oana